



P. O. Box 3800
121 S. Bonham
Amarillo, TX 79116
806.372.2904
fax 806.371.0424
engineering@spectrumsystem.com

Daniel McCracken, P.E.
Neishay White, CD

Mike Ritter
Playa Design
Amarillo, Texas
November 29, 2016

Re: 7th & Polk Restaurant Development – Electrical Addendum #2.

Dear Mike:

Please note the following electrical items for Addendum #2 for the 7th & Polk Restaurant Development Electrical.

1. Disregard all previous electrical addenda and plans issued for this project. All items have been incorporated in this new plan issue. Specifications are not changed and re-released except where noted below.
2. A new complete set of plans dated 11/29/2016 are included with this addendum. Significant changes have been made on this new issue. Revision changes have not been clouded. This plan shall be reviewed completely and no assumptions from previous plans or addenda shall be made.
3. General revisions:
 - a. These plans are considered a shell package. Some items have been removed from this package and deferred to a future tenant finish package.
 - b. All electrical, fire alarm, special systems rough-in, and lighting are relocated to accommodate the changes in the floor plan.
 - c. Panel circuit breakers and some panel specifications have been revised.
 - d. Some light fixture catalog numbers have changed.
 - e. Brewery equipment have been deferred to the tenant finish phase. The Brewery panel remains in the project.
 - f. Site changes have been made to reflect architectural plan changes.
 - g. Schematics and more details have been added.
 - h. Receptacles and lighting have been added.
4. Specification notes
 - a. Lighting control specifications are on the plans.
 - b. There is no lightning protection system.

Sincerely,

A handwritten signature in blue ink that reads "Daniel G. McCracken".

Spectrum Engineering



THE SEAL APPEARING ON THIS DOCUMENT
WAS AUTHORIZED BY
DANIEL G. MCCRACKEN P.E. ON 11/29/2016