


May 7, 2018

Renovation to Tierra Blanca  
615 Columbia Drive  
Hereford, Texas  
CHA# 1728



**ChapmanHarvey**  
ARCHITECTS, INC.

Bids Due \*\*\* May 8, 2018 2:00 pm \*\*\*

Bid Documents dated: 4/25/18

**Addendum Two**

The following shall be incorporated in and become a part of the original Drawings and Specifications of the above identified project. Please acknowledge receipt of this Addendum by noting it on your proposal.

Attached:

1. All aluminum doors to be medium stile doors.
2. On the finish schedule legend F1 should refer to Carpet and F2 should refer to Sheet vinyl. Finishes shown on the floor finish diagram are correct.
3. In the Aluminum Door Section 08410-4 2.8.A.1 & 2 Delete Items 1 & 2 and add:  
"See Section 08700 for specified Finish Hardware"
4. Frames for doors 92 and 93 to be frame 4.
5. Concrete to be as indicated on structural notes S.02.
6. At slab extension – provide and install every 24" OC either 5/8" round dowel bars or #5 rebar – 6" epoxy embedment into existing slab – extend 18" into new slab.

**End of Addendum One**

612 Broadway

Lubbock, Texas 79401

806.749.1153 fax 749.1866

architect@chapmanharvey.com