

**HEREFORD I.S.D. 2018 BOND PACKAGE 1  
WEST CENTRAL ELEMENTARY SCHOOL  
HEREFORD, TEXAS**

BSA Consulting Engineers, PLLC  
Texas Firm Registration No. F-4415  
BSA Project No. 19-020

**ADDENDUM**

April 24, 2019

**NOTICE TO BIDDERS:**

The following shall be incorporated in and become a part of the original Drawings and Specifications of the above identified project. Please acknowledge receipt of this Addendum by noting it on your Proposal.

**Mechanical Item:**

Item 1: On the drawings, Sheet M101W, add the following to General Notes – Plumbing:

- “D. THE ENTIRE BUILDING ADDITION SHALL BE FULLY SPRINKLED IN FULL COMPLIANCE WITH NFPA 13. THE EXISTING BUILDING HAS A FIRE SPRINKLER SYSTEM. EXTEND THE EXISTING SYSTEM, AS NEEDED, TO PROVIDE COVERAGE OF THE BUILDING ADDITION. THE FIRE PROTECTION SYSTEM SHALL BE INSTALLED BY AN EXPERIENCED FIRM REGULARLY ENGAGED IN THE INSTALLATION AND DESIGN OF AUTOMATIC SPRINKLER SYSTEMS. THE CONTRACTOR SHALL HAVE A "CERTIFICATE OF REGISTRATION" OR PROOF OF QUALIFICATIONS AS REQUIRED BY THE STATE OR THE FIRE MARSHAL. THE FIRE PROTECTION DESIGN AND LAYOUT SHALL HAVE THE APPROVAL OF THE ENGINEER AND FIRE MARSHAL. THE ENGINEER MAY REJECT ANY PROPOSED INSTALLER WHO CANNOT SHOW EVIDENCE OF SUCH QUALIFICATIONS.”

End of BSA Mechanical Addendum

