

REYNOLDS ENGINEERING ASSOCIATES, INC.
Electrical Engineers & Consultants

Street Address: 3505 Olsen Blvd., Suite 222, Amarillo, TX 79109
Mailing Address: PO Box 10168, Amarillo, TX 79116-0168
Phone: 806.353.2423 Fax: 806.353.2465 e-mail: parman@engineeringamarillo.com
Firm Engineering Registrations: Texas F-497; Oklahoma CA 4089 PE

July 20, 2017

MEMO TO: John Jenkins, AIA
Lavin Architects

FROM: Parman Reynolds, P.E.

SUBJECT: Addendum #3
Maxor Mail Order Facility
406 S. Tyler, Amarillo

Please instruct the bidders to include the following equipment connection with their bids:

1. Ref. Sheet E2.6:
 - a. A roof mounted exhaust fan, EF-5, is added to Compressor 120. The fan is rated 1/2HP 115V.
 - b. Fan is furnished with a factory hood disconnect. Provide a 120V relay with minimum 10A normally closed line contact and 24VAC coil. Relay is picked up (circuit turned off) by Division 15 EMS.
 - c. Homerun 2-12, 1-12GND, 1/2"C. to spare 20/1 circuit breaker HVB-60.
 - d. Add a wall j-box and wall conduit for a space temperature sensor, with location in the room per the mechanical drawing addendum.

END OF ADDENDUM #3

